

Addendum 1

Exhibit A

BID TAB

FIRM: _____

ADDRESS: _____

TELEPHONE: _____ Fax _____

BASE BID

| | DESCRIPTION OF SERVICES | QUANTITY | TOTAL COST |
|---|--|----------|------------|
| 1 | Coat interior of 500,000 gallon storage tank (60ft diameter X 24 ft height) per section 2.02 A 1 | 2 | |
| 2 | Coat exterior of 500,000 gallon storage tank (60ft diameter X 24 ft height) per section 2.03 A 1 | 2 | |
| 3 | Coat exterior of 1 million gallon storage tank (84ft diameter X 24 ft height) per section 2.03 A 1 | 1 | |
| 4 | Remove existing 8" overflow and replace with 16" diameter overflow, match existing height of 1 million gallon overflow | 2 | |
| 5 | Remove existing 24" air vent and replace bolts on beams around dollar plate and install new 36" air vent | 2 | |
| 6 | Coat all exterior tank piping | 2 | |
| 7 | Install new cathodic protection system per section 4 | 2 | |
| 8 | Coat existing booster pump station and hydro-tank per section 2.03 A 1 | 1 | |
| 9 | Replace existing aluminum gauge board and float system | 2 | |

TOTAL BASE LUMP SUM BID \$ _____

Total Base Lump Sum Bid in Words: _____

Signature _____ Date _____

Printed Name _____ Title _____

Alternative Bid Price Items (Do not include in Base Bid)

| | DESCRIPTION OF SERVICES | QUANTITY | TOTAL COST |
|----|---|-----------------|------------|
| 10 | Cost per API 653 12" round steel plates | 0-5 | Per unit |
| 11 | Cost per API 653 23.5" round steel plates | 0-5 | Per unit |
| 12 | Cost per API 653 12" round steel plates | 0-5 and greater | Per unit |
| 13 | Cost per API 653 23.5" round steel plates | 0-5 and greater | Per unit |