



NOTE:  
 Minimum Depth Of Cover Over 6-Inch and 8-Inch Mains is 36 Inches,  
 12-Inch and Larger is 48 Inches Unless Otherwise Specified.



**STANDARD DETAIL**

FOR THE INSTALLATION OF

3-INCH THRU 10-INCH REDUCED PRESSURE PRINCIPLE-DETECTOR WITH BYPASS METER ASSEMBLY (RPDA) FOR FIRELINE SERVICES

DRAWN BY: CB	APPROVED BY: ML	DATE: 10-26-2021	W-1-1003
-----------------	--------------------	---------------------	----------