



# Water Quality Report 2016

Presented By

PWS ID: AZ04-11-039

## Apache Junction Water District

The Apache Junction Water District (AJWD) is pleased to present the annual drinking water quality report (Consumer Confidence Report) for calendar year 2016. This report contains important information about the quality of your drinking water.

Este informe contiene información muy important sobre el agua usted bebe. Debe traducirlo o hablar con alguien que lo entienda bien.

### Why Provide a Water Quality Report?

To ensure that tap water is safe to drink, the United States Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

We want our valued customers to be informed about their water quality and its health effects.

If you would like to learn more about our system, how to help protect your drinking water sources, attend any of our regularly scheduled meetings, or any details presented in this report, please contact our office at (480) 982-6030.



### Where Does AJWD Water Come From?

AJWD supplies well water (groundwater) pumped from the Eastern Salt River Sub-Basin Aquifer which flows southwesterly under Apache Junction and its surrounding areas. The groundwater is treated for arsenic removal where necessary, disinfected with chlorine, pumped into storage tanks and blended with Colorado River (surface) water. The surface water is transported through the Central Arizona Project (CAP) canal system and filtered and purified at the Superstition Area Water Plant before being introduced into the distribution system.

AJWD can also receive CAP water from the City of Mesa's Brown Road Treatment Plant and delivered through an interconnect for a backup supply of water, if needed.

### Source Water Assessment

In 2004, the Arizona Department of Environmental Quality (ADEQ) completed a source water assessment (SWA) of our water system to identify potential sources of contaminants to our drinking water. In this assessment, ADEQ reviewed the adjacent land use that may pose a potential risk to our water sources.

Based on the SWA, ADEQ has given AJWD a low risk designation for our source water. A low risk designation indicates that most source water protection measures are either already implemented or the hydrogeological setting is such that it protects the source water. This assessment report provides a one time evaluation of our source water.

With the addition of the Superstition Area Water Plant, AJWD has added a new source water to its system. In 2017, AJWD will conduct a new SWA with ADEQ to evaluate and include this new source water. Further source water assessment documentation can be obtained by contacting ADEQ at (602) 771-4641.

## What Could Be in Drinking Water Sources?

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- ◆ **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ◆ **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- ◆ **Pesticides and herbicides**, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- ◆ **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.
- ◆ **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

## Should I Take Special Precautions for My Health?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the EPA and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants, call the EPA Safe Drinking Water Hotline at 1-800-426-4791.

## Additional Health Information on Contaminants of Concern

- **Cryptosporidium:** We detected *Cryptosporidium* in the source water. Our sampling of our surface water source began at the Superstition Area Water Plant in October 2016. In our 3 monthly samples taken in 2016, we detected *Cryptosporidium* in 0 of our 3 samples tested. We have to provide additional treatment if *Cryptosporidium* is found at greater than 0.075 oocyst per liter. We believe it is important for you to know that *Cryptosporidium* may cause serious illness in immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. These people should seek advice from their health care providers.
- **Nitrate:** Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.
- **Arsenic:** If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.
- **Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home in plumbing. AJWD is responsible for providing high quality drinking water, but cannot control the variety of materials used in residential plumbing components. When your water has been sitting for several hours, you can reduce the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Important Information About Your Drinking Water

### **Monitoring Requirements Not Met for AJWD**

AJWD is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) samples are collected quarterly every 90 days, per the EPA Stage 2 Disinfection Byproduct Rule. To meet the 90 day requirement, 1<sup>st</sup> Quarter TTHM and HAA5 samples should have been collected on January 12, 2016. AJWD collected 1<sup>st</sup> Quarter 2016 TTHM and HAA5 samples on March 15, 2016; therefore, in January 2016, AJWD did not complete all TTHM and HAA5 monitoring. The March sample results were below the Maximum Contaminant Level (MCL) and your water meets drinking water standards.

To meet routine sampling requirements of the Revised Total Coliform Rule, AJWD should have collected a sample during the month of December. A sample for Total Coliform Bacteria (& E. coli) was collected on November 30, 2016; therefore, AJWD did not complete all monitoring requirements for Total Coliform Bacteria in December 2016. The November 30, 2016 sample was absent of Total Coliform Bacteria.

Since these two samples were not taken on their scheduled dates, they are considered missed monitoring violations. AJWD cannot technically be sure of the quality of your drinking water during the time of the missed monitoring. Although these incidents were not emergencies, as our customers, you have a right to know what happened and what we did to correct the situation.

### **What should I do?**

There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours. We will announce any emergencies on local television and radio station. We will also post this information on our website at [www.ajwaterdistrict.org](http://www.ajwaterdistrict.org).

### **What is being done?**

AJWD has since taken the subsequent samples during the required timeframe. The 2<sup>nd</sup> Quarter 2016 TTHM and HAA5 samples and the monthly January 2017 samples for Total Coliform Bacteria (& E. coli) were collected on the correct schedule. The results of those samples showed AJWD is still meeting all drinking water standards.

For more information, please contact AJWD at 480-982-6030 or [webmailwater@ajcity.net](mailto:webmailwater@ajcity.net).

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

## Definitions and Acronyms

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

**Action Level Goal (ALG)**

**Average (Avg)**

**Locational Running Annual Average (LRAA):** Average of sample analytical results samples taken at a specific monitoring location during the previous 4 calendar quarters.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health.

**Maximum Residual Disinfectant Level (MRDL):** The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur.

**Milligrams per Liter (mg/L)**

**Nephelometric Turbidity Units (NTU):** A measure of water clarity.

**Not Applicable (NA):** Sampling was not completed by regulation or was not required.

**Not Detected (ND)**

**Parts Per Million (ppm)** or Milligrams per liter (mg/L).

**Parts Per Billion (ppb):** ppm x 1000

**Pico Curies per Liter (pCi/L)**

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

# Regulated Drinking Water Contaminants

All Following Results Meet Regulatory Standards

AJWD [1]			City of Mesa					
			Brown Road WTP	Eastern Zone Wells	Distribution System			
<b>INORGANIC CHEMICALS</b>								
Parameter	MCL	MCLG	Range (Avg)	Range (Avg) [2]	Range (Avg) [3]	Range (Avg)	Likely Source in Drinking Water	
Arsenic (ppb)	10	0	1.3-4.3 (3.04)	ND	1.2-7.3 (4.4)	<b>NA</b>	Erosion of natural deposits; Runoff from orchards	
Barium (ppb)	2000	2000	130-130 (130)	130	2.0-44 (11)		Erosion of natural deposits; Discharge of drilling wastes	
Chromium, Total (ppb)	100	100	ND	ND	2.0-23 (12)		Erosion of natural deposits; Discharge from steel mills	
Fluoride (Naturally Occurring) (ppm)	4	4	0.71-0.82 (0.77)	NA	0.29-1.2 (0.52)		Erosion of natural deposits; Discharge from fertilizer factories	
Nitrate (measured as Nitrogen) (ppm)	10	10	0.4-0.44 (0.42)	0.2	0.8-4.1 (1.9)		Runoff from fertilizer use; Leaking from septic tanks	
Selenium (ppb)	50	50	3.8-3.8 (3.8)	1.9	ND		Erosion of natural deposits; Discharge from mines	
<b>RADIONUCLIDES</b>								
Parameter	MCL	MCLG	Range (Avg)	Range (Avg) [4]	Range (Avg) [4]	Range (Avg)	Likely Source in Drinking Water	
Alpha Particles (pCi/L)	15	0	3.5-3.7 (3.57)	3.6	ND - 4.4 (1.8)	<b>NA</b>	Erosion of natural deposits	
Combined Radium (pCi/L)	5	0	ND	ND	ND		Erosion of natural deposits	
<b>DISINFECTANTS &amp; DISINFECTION BYPRODUCTS</b>								
Parameter	MRDL	MRDLG	Range (Avg)	Range (Avg) [2]		Range (Avg) [2]	Likely Source in Drinking Water	
Free Chlorine Residual (ppm)	4	4	0.65-0.95 (0.79)	ND-2.1 (0.9)	<b>NA</b>	ND-2.7 (0.92)	Water additive used to control microbes	
Chlorine Dioxide (ppb)	800	800	<b>NA</b>	ND-400 (NA)		NA	Water additive used to control microbes	
Chlorite (ppm)	MCL=1	MCLG=0.8		0.02-0.5 (0.2)		0.02-0.5 (0.2)	Byproduct of chlorine dioxide disinfection	
Parameter	MCL	MCLG	Range (Highest Level)	Range (Highest Level)			Range (Highest Level) [2]	Likely Source in Drinking Water
Haloacetic Acids (HAA5) (ppb)	LRAA = 60	NA	16.6-31.4 (23.5)	<b>NA</b>			ND-26 (22)	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHMs) (ppb)	LRAA = 80	NA	38.2-106.0 (69.2)					8.4-104 (78)
<b>LEAD &amp; COPPER</b>								
Parameter	AL	ALG	Range (90th Percentile)			Range (90th Percentile) [2]	Likely Source in Drinking Water	
Lead (ppb)	15	0	ND-380 (7.7)	<b>NA</b>	<b>NA</b>	ND-7.6 (4.2)	Erosion; Corrosion of household plumbing systems	
Copper (ppb)	1300	1300	39-1210 (263)					7.5-163 (90)
<b>TURBIDITY</b>								
Facility	MCL	MCLG	Monthly Measurement % ≤0.3 NTU	Highest Monthly Measurement	Likely Source in Drinking Water			
AJWD Superstition Area Water Plant	TT: At least 95% of monthly samples must be ≤0.3 NTU and No value can exceed 1 NTU		100%	0.3 NTU	Soil Runoff			
City of Mesa Brown Road Water Treatment Plant [2]			100%	0.1 NTU	Soil Runoff			
<b>TOTAL COLIFORM BACTERIA</b>								
System	MCL	MCLG	Highest Monthly #	Highest Monthly %	Likely Source in Drinking Water			
Apache Junction Water District	< 1 Monthly	0	0	NA	Naturally present in environment			
City of Mesa Distribution System [2]	< 5% Monthly	0	6	0.95%	Naturally present in environment			

[1] All AJWD samples were taken in 2016. [2] 2016 Sampling Data [3] 2015-2016 Sampling Data [4] 2012-2014 Sampling Data